DEKRA KRA DI DEKRA

EKRA D

DEKRA D

# **CERTIFICATE**

Issued to:
Applicant:
Zhejiang Chint Electrics Co., Ltd.
No 1 Chint Road, Chint Industrial Zone, North
Baixiang, Yueqing, Zhejiang Province, P.R.
China

Manufacturer/Licensee:
Noark Electrics (Shanghai) Co., Ltd.
3857 Sixian Road, Songjiang District, Shanghai,
P.R. China

Product(s) : Air Circuit Breaker

Trade name(s) : CHINT Type(s)/model(s) : NA8-7500

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of

- a type test according to the standard EN 60947-2:2006 + A1:2009 + A2:2013; IEC 60947-2:2006 + A1:2009 + A2:2013; EN 60947-5-1:2004 + A1:2009; IEC 60947-5-1:2003 + A1:2009
- an inspection of the production location according to CENELEC Operational Document OIG 021
- a certification agreement with the number 2130446

DEKRA hereby grants the right to use the KEMA-KEUR certification mark

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 24 September 2015 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 3308087.01

DEKRA Certification B.V.

drs. G.J. Zoetbrood Managing Director F.S. Strikwerda Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE DUTCH ACCREDITATION COUNCIL







## ANNEX TO KEMA-KEUR CERTIFICATE 3308087.01

page 1 of 3

#### SPECIFICATION OF THE CERTIFIED PRODUCT

**Product data** 

Air Circuit Breaker product

trade name(s) CHINT type(s) NA8-7500

number of poles 3 P and 4P (protected N pole)

protected pole 3 or 4

380 Vac / 400 Vac / 415 Vac / 660 Vac / 690 Vac rated operational voltage (Ue)

rated insulation voltage (Ui) 1000 V for main circuit

415 V for control circuits and auxiliary circuits

rated impulse withstand voltage 12 kV for main circuit

(Uimp)

6 kV for control circuits and auxiliary circuits 4000 A, 5000 A, 6300 A, 7500 A rated current (In)

rated operational current (le)  $(0.4 - 1.0) \times In$ conventional thermal current (Ith) Equal to In

current rating for four-pole circuit-Equal to In for 4000 - 6300 A, Equal to 50% In for 7500 A, breakers

rated frequency 50 / 60 Hz

rated ultimate short-circuit breaking 135 kA at 380 / 400 / 415 Vac, 100 kA at 660 / 690 Vac

capacity (Icu) rated service short-circuit breaking

capacity (Ics)

rated short-time withstand current

(lcw)

suitable for isolation Suitable utilization category

safety distance (screen-circuit

breaker)

inverse time delay release Ir (inverse time delay tripping setting):

(0,4,0,5,0,6,0,7,0,8,0,9,0,95,0,98,1,0) x In

time setting of the inverse time

delay release

tr (inverse time delay tripping setting):

1 s, 2 s, 4 s, 8 s, 12 s, 16 s, 20 s, 24 s, 30s with tolerance of ±

135 kA at 380 / 400 / 415 Vac, 100 kA at 660 / 690 Vac

135 kA / 1s at 380 / 400 / 415 Vac. 100 kA / 1s at 660 / 690 Vac

15% (at 6 lr) Trip time at 2 Ir:

All sides: 0 mm

Set at 1 s: 9,0 s, with tolerance of ±15% Set at 30 s: 270 s, with tolerance of ± 15%

short time delay release Isd (short time delay tripping setting):

(1,5, 2, 2,5, 3, 4, 5, 6, 8, 10) x lr

time setting tsd (short time delay tripping setting):

0.1 s, 0.2 s, 0.3 s, 0.4 s, with tolerance of ± 10%

Non-tripping duration: Set at 0,1 s: 0,07 s, Set at 0,4 s: 0,35 s

instantaneous release : li (instantaneous tripping setting):

(2, 3, 4, 6, 8, 10, 12, 15) x ln

MCR release 49 kA

time setting instantaneous

(0,2,0,3,0,4,0,5,0,6,0,7,0,8,0,9,1,0) x In ground fault release

tg: 0,1 s, 0,2 s, 0,3 s, 0,4 s, 0,5 s, 0,6 s, 0,8 s, 1,0 s with

tolerance of ± 10%



#### ANNEX TO KEMA-KEUR CERTIFICATE 3308087.01

page 2 of 3

Fixed or Withdrawable method of mounting

EMC environment Α circuit-breaker for use on phase-N/A

earthed systems

circuit-breaker for use in IT systems Yes, 50 kA at 415 Vac

reference temperature Independent

shunt release AC: 220 - 230 V, 380 - 415 V, 50 / 60 Hz

DC: 110 V, 220 V

under-voltage release AC: 220 - 230 V, 380 - 415 V, 50 / 60 Hz AC: 220 - 230 V, 380 - 415 V, 50 / 60 Hz closing coil

DC: 110 V, 220 V

stored energy motor AC: 220 - 230 V, 380 - 415 V, 50 / 60 Hz

DC: 110 V, 220 V

auxiliary circuits Utilization category:

AC-15: 1,3 A at 230 Vac, 0,75 at 415 Vac, 50 / 60 Hz

DC-13: 0,55 A at 110 Vdc, 0,27 A at 220 Vdc

number and kind of contact elements: 4 NO and 4 NC or 6 NO and 6 NC rated conditional short-circuit current: 1 kA

conventional free air thermal current (Ith): 6 A kind of protective device: fuse, RL6-25/6, gG, 6 A, 500 V

External supply for trip unit AC: 220 - 230 V, 380 - 415 V, 50 / 60 Hz DC: 110 V, 220 V

line/load terminal Immaterial connection Copper busbar

(100 x 10) mm<sup>2</sup> x 8 for In of 4000 A - 6300 A (100 x 10) mm<sup>2</sup> x 10 for In of 7500 A

rated tightening torque for terminals : 45 Nm



## ANNEX TO KEMA-KEUR CERTIFICATE 3308087.01

page 3 of 3

## **TESTS**

# **Test requirements**

EN 60947-2:2006 + A1:2009 + A2:2013 EN 60947-5-1:2004 + A1:2009 IEC 60947-2:2006 + A1:2009 + A2:2013 IEC 60947-5-1:2003 + A1:2009

# **Test result**

The test results are laid down in DEKRA test file 3308087.01.

#### Remarks

This certificate is based on certificate no. 3307784.01 issued on 2015-07-31.

## Conclusion

The examination proved that all test requirements were met.

Tested by : King Wang

Checked by : Eric Wang

**Factory locations** 

Noark Electrics (Shanghai) Co., Ltd. 3857 Sixian Road, Songjiang District, Shanghai, P.R. China