



Ref. Certif. No.

SE-87111

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded case circuit breakers

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road, Chint Industrial Zone, North Baixia
Yueqing, Zhejiang Province,
P.R.CHINA

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

U_e= 240V~(1P), 415V~(2P, 3P, 4P)
I_n= 1, 2, 3, 4, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63A
I_{cs}= I_{cu}= 6kA, U_i= 500V, Cat. A, 50/60Hz

Trademark (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

NB1-63

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

170302432SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Intertek

Signature:

Bo Berglöf

Date: 24 May 2017