

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product Produit	Residual current circuit breakers with integral overcurrent protection (RCBO)
Name and address of the Applicant Nom et adresse du demandeur	Zhejiang Chint Electrics Co., Ltd No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang China
Name and address of the manufacturer Nom et adresse du fabricant	Zhejiang Chint Electrics Co., Ltd No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang China
Name and address of the factory Nom et adresse de l'usine	Zhejiang Chint Electrics Co., Ltd No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang China
Rating and principal characteristics Valeurs nominales et caractéristiques principales	1P + N Ue = 220 / 230 / 240 Vac, 50 Hz In = 2, 4, 6, 10, 13, 16, 20, 25, 32, 40 A B and C - type I Δ n = 30, 100, 300 mA Type A and AC, without time-delay Ics = 6000 A or 7500 A , Icn = 6000 A or 10000 A I Δ m = 3000 A Safety grid distance "a" = 50 mm Temperature limit: - 25 °C ... + 40 °C (-25°C was tested according to EN61009-1) Reference ambient temperature: 30 °C
Trademark (if any) Marque de fabrique (si elle existe)	CHINT
Type of manufacturer's Testing Laboratories used Type de programme de laboratoire d'essais constructeur	
Model / Type Ref. Réf. de type	NB1L
Additional information (if necessary may also be reported on page 2) Les informations complémentaires (si nécessaire, peuvent être indiquées sur la 2ème page)	Energy limiting class 3 according to EN 61009-1. The certificate replaces CB certificate no. NL-33198 issued on 2014-10-28.
A sample of product was tested and found to be in conformity with IEC Un échantillon de ce produit a été essayé et été considéré conforme à la CEI	61009-1(ed.3);am1;am2 61009 2 1(ed.1)
As shown in the test report Ref. No. which forms part of this certificate Comme indiqué dans le rapport d'essais numéro de référence qui constitue partie de ce certificat	3310241.50, 3306652.50, 3302588.52, 3302588.50 and W0811042.50

This CB Test Certificate is issued by the National Certification Body:

Ce Certificat d'essai OC est établi par l'Organisme National de Certification

 DEKRA Certification B.V.
 Meander 1051, 6825 MJ
 Arnhem
 The Netherlands


Date: 2016-08-10

Signature: H.L. Schendstok

