

CERTIFICATE

Issued to:
Applicant:
Zhejiang CHINT Electric Co., Ltd.
No.1, Chint Road, CHINT Industrial Zone, North
Baixiang, Yueqing, Zhejiang Province,
P.R.CHINA

Manufacturer/Licensee:
Zhejiang CHINT Electric Co., Ltd.
No.1, Chint Road, CHINT Industrial Zone, North
Baixiang, Yueqing, Zhejiang Province,
P.R.CHINA

Product(s) : Electromagnetic contactor
Trade name(s) : CHINT
Type(s)/model(s) : NC8-09, NC8-12, NC8-18

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-4-1:2010 + A1:2012; EN 60947-5-1:2004 + A1:2009; IEC 60947-4-1:2009 + A1:2012; IEC 60947-5-1:2003 + A1:2009;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2032236

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.


This certificate is issued on: 9 April 2015 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 3307298.01

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



F.S. Strikwerda
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

| | | |
|---|---|--|
| product | : | Electromagnetic contactor |
| trade name(s) | : | CHINT |
| type(s) | : | NC8-09, NC8-12, NC8-18 |
| General | : | |
| method of operation | : | Electromagnetic |
| pollution degree | : | 3 |
| main circuit | : | |
| number of poles | : | 3, 4 |
| rated frequency | : | 50/60 Hz |
| rated operational voltage (Ue) | : | 220/230/240 Vac; 380/400/415 Vac and 660/690 Vac |
| rated insulation voltage (Ui) | : | 690 V |
| rated impulse withstand voltage (Uimp) | : | 6 kV |
| auxiliary circuit | : | |
| rated frequency | : | 50/60 Hz |
| utilization category | : | AC-15, DC-13 |
| conventional thermal current (Ith) | : | 10 A |
| rated current (Ie) | : | AC-15: 0,95 A, 415 Vac; DC-13: 0,27 A, 250 Vdc |
| rated uninterrupted current (Iu) | : | AC-15: 0,95 A, 415 Vac; DC-13: 0,27 A, 250 Vdc |
| rated conditional short-circuit current | : | 1 kA with fuse RT36-00 (NT00 gG 10 A 120 kA at 500 Vac) |
| control circuits | : | |
| kind of current | : | AC, DC |
| rated frequency | : | 50/60 Hz |
| rated control supply voltage (Us) | : | 24, 110, 127, 220/230, 240, 380/400, 415 Vac 24, 48, 110, 220 Vdc |

Additional information

Nomenclature breakdown

NC8-ab/c/d/e

a= Rated operational current at AC-3, 380/400/415 Vac

b= Number of auxiliary contacts

11=1NO+1NC; 22=2NO+2NC, 4P contactor has no auxiliary contact (omitted)

c= Number of main contacts

Nil=3NO; 4=4NO; 22= 2NO+2NC

d= Z: coil is DC, B is general type (omitted)

e= N means the reversing type, Nil means not reversing

Product data - type NC8-09

| | | |
|---|---|---|
| rated operational current I_e (A) | : | 9 A at 220/230/240, 380/400/415 Vac (AC-3 and AC-4) 6,7 A at 660/690 Vac (AC-3 and AC-4) |
| conventional thermal current (I _{th}) | : | 25 A |
| rated conditional short-circuit current ("r") | : | 1 kA |
| rated conditional short-circuit current ("I _q ") | : | 50 kA |
| type of co-ordination | : | 1 |
| SCPD | : | Fuse RT36-00(NT00), gG 32 A, 50 kA at 690 Vac |
| Terminal | : | Rigid or copper conductor with cable lug Largest: 6 mm ² /1, smallest: 1 mm ² /2 |

Product data - type NC8-12

| | | |
|---|---|---|
| rated operational current I_e (A) | : | 12 A at 220/230/240, 380/400/415 Vac (AC-3 and AC-4) 9 A at 660/690 Vdc (AC-3 and AC-4) |
| conventional thermal current (I _{th}) | : | 25 A |
| rated conditional short-circuit current ("r") | : | 1 kA |
| rated conditional short-circuit current ("I _q ") | : | 50 kA |
| type of co-ordination | : | 1 |
| SCPD | : | Fuse RT36-00(NT00), gG 32 A, 50 kA at 690 Vac |
| Terminal | : | Rigid or copper conductor with cable lug Largest: 6 mm ² /1, smallest: 1 mm ² /2 |

Product data - type NC8-18

| | | |
|---|---|---|
| rated operational current I_e (A) | : | 18 A at 220/230/240, 380/400/415 Vac (AC-3 and AC-4) 10,6 A at 660/690 Vdc (AC-3 and AC-4) |
| conventional thermal current (I _{th}) | : | 32 A |
| rated conditional short-circuit current ("r") | : | 1 kA |
| rated conditional short-circuit current ("I _q ") | : | 50 kA |
| type of co-ordination | : | 1 |
| SCPD | : | Fuse RT36-00(NT00), gG 32 A, 50 kA at 690 Vac |
| Terminal | : | Rigid or copper conductor with cable lug Largest: 6 mm ² /1, smallest: 1 mm ² /2 |

TESTS**Test requirements**

EN 60947-4-1:2010 + A1:2012
EN 60947-5-1:2004 + A1:2009
IEC 60947-4-1:2009 + A1:2012
IEC 60947-5-1:2003 + A1:2009

Test result

The test results are laid down in DEKRA test file 3307298.01 and test reports No. 3307298.50, W0809035.51 and 3303082.51

Remarks

This certificate replaces the KEMA-KEUR certificate no. 2151908.01 issued on 2012-03-05.

Conclusion

The examination proved that all test requirements were met.

Tested by : Max Ma



Checked by : Eric Wang

**Factory locations**

Zhejiang CHINT Electrics Co., Ltd.

No.1, Chint Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.CHINA